

PROHLÁŠENÍ O SHODĚ A PRODUKTOVÝ LIST

Nitrilové rukavice NITRIL ^{DIAMOND 3}

ČÁST I: POPIS PRODUKTU

Typ:	jednorázové nesterilní ochranné a vyšetřovací rukavice
Materiál:	100% syntetický nitril
Barva:	oranžová
Provedení:	pravolevé, diamantový vzor, korálková manžeta
Pudr:	není přidán
Skladování:	rukavice neztrácejí své vlastnosti při skladování v suchu při teplotě od 10 do 30 °C
Životnost:	5 let od data výroby při dodržení podmínek skladování
Balení:	100 ks v krabičce, 10 krabiček v kartonu

ČÁST II: SPECIFIKACE PRODUKTU

Délka (mm):	min. 240
Šířka (mm):	XS – 77 ± 10 S – 85 ± 10 M – 95 ± 10 L – 110 ± 10 XL – 120 ± 10
Tloušťka (mm):	prsty: 0.12 ± 0.05 (typická hodnota 0.11 – 0.14) dlaň: 0.25 ± 0.05 (typická hodnota 0.23 – 0.25)
Prodloužení do přetržení (%):	min. 500
Pevnost v tahu (MPa):	min. 6
AQL:	1.5

ČÁST III: NORMY A NAŘÍZENÍ

Tímto potvrzujeme, že výše uvedený výrobek je v souladu s:

Obecné: PPER (EU) 2016/425 Cat. III
 EN420
 EN 1186-2,9:2002
 EN 10130-1:2004
 EN 388:2016+A1:2018
 EN ISO 374-1,5:2016+A1:2018
 EN ISO 374-2,4:2019

Potravinářství: EC 1935/2004
 EU 10/2011 * Vyhovuje pro všechny simulanty kromě 3% kyseliny octové. Tento produkt je vhodný pro manipulaci s potravinami, kromě kyselých potravin (testováno 2 hodiny při 40 ° C)

ČÁST IV: POLOŽKY

Pol. č.	Velikost	Hmotnost (g)	Rozměry (mm)	Kvalita (g)	EAN
100165	M	860	240x140x110	8.0 ± 0.3	8594177201626
100166	L	890	240x140x110	8.3 ± 0.3	8594177201633
100167	XL	920	240x140x110	8.6 ± 0.3	8594177201640

ČÁST V: NÁHLED PRODUKTU





ČÁST VI: PŮVOD PRODUKTU

Výrobce:

INTCO Medical Technology Co., Ltd, No. 29 Zhangliu Road, Zibo, Shandong, China

Distributor:

Espeon s.r.o., U větrolamu 1212/53, 184 00 Praha 8, info@espeon.cz , www.espeon.cz

Customer details: SATRA Technology Services (Dongguan) Ltd SATRA reference: CHM0330968/2219/JL
Unit 110, Xinzhongyin Garden
Hongwei Road
Xiping, Nancheng District
DONGGUAN CITY
Guangdong Province
China
523079

Your reference: CHT0328812
Date of report: 17th May 2022
Samples received: 11th April 2022
Date(s) work carried out: 14th to 16th May 2022

TECHNICAL REPORT

SATRA Technology Services (Dongguan) Ltd:

Customer: Shandong Intoo Medical Products Co Ltd
Qiwang Road, Naoshan Industrial Park
Qingzhou
Shandong
262506
China

Subject: EN ISO 374-4:2019 determination of resistance to degradation by dangerous chemicals on gloves described as Nitrile gloves, colour: orange, black.

Conditions of Issue:

This report may be forwarded to other parties provided that it is not changed in any way. It must not be published, for example by including it in advertisements, without the prior, written permission of SATRA.

Results given in this report refer only to the samples submitted for analysis and tested by SATRA. Comments are for guidance only.

Tests marked # fall outside the UKAS Accreditation Schedule for SATRA.

All opinions and interpretations of results, and the comments based upon them are outside the scope of UKAS accreditation and are based on current SATRA knowledge.

A satisfactory test report in no way implies that the product tested is approved by SATRA and no warranty is given as to the performance of the product tested. SATRA shall not be liable for any subsequent loss or damage incurred by the client as a result of information supplied in the report.

Where values for uncertainty of measurement are included within the report then the uncertainty of the corresponding results are based on a standard uncertainty multiplied by a coverage factor $k=2$, which provides a coverage probability of approximately 95%.

When reporting results against a conformance statement (Pass/Fail or the allocation of a class or level) then uncertainty of measurement is taken into account based on a non-binary acceptance which itself is based on the guard band being equal to the expanded uncertainty.

Where the result corrected for uncertainty falls within the tolerance of the conformance statement then the risk of the conformance statement being a false accept or false reject is up to 2.5% and SATRA will in this instance quote a Pass/Fail, class or level.

Where the result corrected for uncertainty falls outside of the tolerance of the conformance statement then the risk of the conformance statement being a false accept or false reject is up to 50%. In this instance SATRA will not provide a Pass/Fail statement or a class or level but will include information in the notes in relation to the result obtained.

Please note that where uncertainty of measurement values have not been included then uncertainty has not been applied to these results. SATRA uncertainty of measurement values are however available upon request.

Report signed by: Jennifer Lewis
Position: Technical Administrator
Department: Chemical & Analytical Technology

(Page 1 of 6)

WORK REQUESTED:

Samples of gloves described as Nitrile gloves, colour: orange, black were received on the 11th April 2022 for testing in accordance with EN ISO 374-4:2019.

SAMPLE SUBMITTED:



Sample described as Nitrile gloves, colour: orange, black.


CONCLUSION:

When assessed in accordance with EN ISO 374-4:2019 the samples of gloves described as Nitrile gloves, colour: orange, black achieved the following degradation results:

Chemical	Mean degradation / %
40% Sodium hydroxide (CAS: 1310-73-2)	-7.1
25% Ammonium hydroxide (CAS: 1336-21-6)	27.0
37% Formaldehyde (CAS: 50-00-0)	17.7
30% Hydrogen peroxide (CAS: 7722-84-1)	27.1
96% Sulphuric acid (CAS: 7664-93-9)	100.0

TESTING REQUIRED:

- EN ISO 374-4:2019. Protective gloves against dangerous chemicals and micro-organisms. Part 4: Determination of resistance to degradation by chemicals.



RESULTS:

Sample description:	Nitrile gloves, colour: orange, black		
Challenge chemical:	40% Sodium hydroxide (CAS: 1310-73-2)		
Test temperature / °C:	(23 ± 1)		
Degradation / %:	Glove 1	Glove 2	Glove 3
	-12.1	-14.6	5.3
Mean degradation (DR) / %:	-7.1		
Standard deviation (σ_{DR}) / %:	10.8		
UoM / ± %:	5.6		
Appearance of samples after testing:	No change		


Sample description:	Nitrile gloves, colour: orange, black		
Challenge chemical:	25% Ammonium hydroxide (CAS: 1336-21-6)		
Test temperature / °C:	(23 ± 1)		
Degradation / %:	Glove 1	Glove 2	Glove 3
	31.7	17.5	32.0
Mean degradation (DR) / %:	27.0		
Standard deviation (σ_{DR}) / %:	8.3		
UoM / ± %:	6.6		
Appearance of samples after testing:	Slightly swollen and discoloured		

Sample description:	Nitrile gloves, colour: orange, black		
Challenge chemical:	37% Formaldehyde (CAS: 50-00-0)		
Test temperature / °C:	(23 ± 1)		
Degradation / %:	Glove 1	Glove 2	Glove 3
	21.5	12.1	19.3
Mean degradation (DR) / %:	17.7		
Standard deviation (σ_{DR}) / %:	4.9		
UoM / ± %:	6.2		
Appearance of samples after testing:	No change		

Sample description:	Nitrile gloves, colour: orange, black		
Challenge chemical:	30% Hydrogen peroxide (CAS: 7722-84-1)		
Test temperature / °C:	(23 ± 1)		
Degradation / %:	Glove 1	Glove 2	Glove 3
	34.4	19.3	27.7
Mean degradation (DR) / %:	27.1		
Standard deviation (σ_{DR}) / %:	7.6		
UoM / ± %:	7.9		
Appearance of samples after testing:	Swollen and discoloured		

Sample description:	Nitrile gloves, colour: orange, black		
Challenge chemical:	96% Sulphuric acid (CAS: 7664-93-9)		
Test temperature / °C:	(23 ± 1)		
Degradation / %:	Glove 1	Glove 2	Glove 3
	100.0	100.0	100.0
Mean degradation (DR) / %:	100.0		
Standard deviation (σ_{DR}) / %:	<1		
UoM / ± %:	N/A		
Appearance of samples after testing:	Softened, swollen, disintegrated and discoloured		

NOTE: Where the test specimens gave an increased puncture force after chemical exposure, the result is reported as a negative degradation.





SATRA Technology Services (Dongguan) Ltd
Unit 110, Xinzhongyuan Garden, Xiping
Nancheng District, Dongguan City
Guangdong Province, China 523079
Tel: +86 (0) 769 22888020
email: info@satrafte.com



Customer details: Shandong Intco Medical Products Co Ltd
Qiwang Road, Naoshan Industrial Park
Qingzhou
Shandong
China
262506

SATRA reference: CHT0328812 /2212/A

Your reference:

Date of report: 12 April 2022

Samples received: 26 March 2022

Date(s) work carried out: 4 April 2022

TECHNICAL REPORT

Subject:

EN 388: 2016+ A1: 2018 abrasion, blade cut, tear and puncture test on nitrile gloves, colour: orange, black, sizes M7, L8, XL9, XXL10.

Conditions of Issue:

This report may be forwarded to other parties provided that it is not changed in any way. It must not be published, for example by including it in advertisements, without the prior, written permission of SATRA.

Results given in this report refer only to the samples submitted for analysis and tested by SATRA. Comments are for guidance only.

Tests marked # fall outside the UKAS Accreditation Schedule for SATRA.

All opinions and interpretations of results, and the comments based upon them are outside the scope of UKAS accreditation and are based on current SATRA knowledge.

A satisfactory test report in no way implies that the product tested is approved by SATRA and no warranty is given as to the performance of the product tested. SATRA shall not be liable for any subsequent loss or damage incurred by the client as a result of information supplied in the report.

Where values for uncertainty of measurement are included within the report then the uncertainty of the corresponding results are based on a standard uncertainty multiplied by a coverage factor $k=2$, which provides a coverage probability of approximately 95%.

When reporting results against a conformance statement (Pass/Fail) then uncertainty of measurement is taken into account based on a non-binary acceptance which itself is based on the guard band being equal to the expanded uncertainty.

Where the result corrected for uncertainty falls within the tolerance of the conformance statement then the risk of the conformance statement being a false accept or false reject is up to 2.5% and SATRA will in this instance quote a Pass/Fail, class or level.

Where the result corrected for uncertainty falls outside of the tolerance of the conformance statement then the risk of the conformance statement being a false accept or false reject is up to 50%. In this instance SATRA will not provide a Pass/Fail statement or a class or level but will include information in the notes in relation to the result obtained.

Please note that where uncertainty of measurement values have not been included then uncertainty has not been applied to these results. SATRA uncertainty of measurement values are however available upon request.

Report signed by: Adam Zhang
Position: Technologist
Department: China Testing

(Page 1 of 6)



WORK REQUESTED

Samples described as nitrile gloves, colour: orange, black, sizes M7, L8, XL9, XXL10 were received by SATRA on 26 March 2022 for testing in accordance with EN 388:2016+A1:2018.

SAMPLE SUBMITTED



TESTING REQUESTED

EN 388:2016 +A1:2018 Clause 6.1 – Abrasion resistance
EN 388:2016 +A1:2018 Clause 6.2 – Blade cut resistance
EN 388:2016 +A1:2018 Clause 6.4 – Tear Resistance
EN 388:2016 +A1:2018 Clause 6.5 – Puncture Resistance

CONCLUSION

The samples described as nitrile gloves, colour: orange, black, sizes M7, L8, XL9, XXL10 were found to achieve the following results:

EN 388:2016+A1:2018 Clause 6.1 – Level 0
EN 388:2016+A1:2018 Clause 6.2 – Level 0
EN 388:2016+A1:2018 Clause 6.4 – Level 0
EN 388:2016+A1:2018 Clause 6.5 – Level 0

Detailed results are included on the following page(s)

TESTING

Testing was carried out in accordance with EN 388:2016+A1:2018.

Samples for testing were conditioned for at least 24 hours in a conditioned environment maintained at (23±2) °C and (50±5) % relative humidity.

REQUIREMENTS

Table 1 – Requirements for EN 388:2016 +A1:2018 Levels of performance

Performance Level	1	2	3	4	5
6.1 Abrasion resistance (number of rubs)	100	500	2000	8000	-
6.2 Coupe test Blade cut resistance (index)	1.2	2.5	5.0	10	20
6.4 Tear resistance (N)	10	25	50	75	-
6.5 Puncture resistance (N)	20	60	100	150	-

TEST RESULTS

Table 2 – EN 388:2016+A1:2018 Test Results

Clause / Test	Test Results			UoM (See note ⬤)	Level		
	Sample	Failure between / cycles	Physical change observed at end point				
6.1 Abrasion resistance	1	105-150	Hole	± 5 %	Level 0		
	2	10-20	Hole				
	3	1-10	Hole				
	4	105-150	Hole				
	Abradant-Klingspor PL31B Gritt 180 Tape-3M 465 Abrasion machine compliant with EN 388:2016 +A1:2018 Clause 6.1.3						
6.2 Blade cut resistance	Sample	C _n Control specimen	Test specimen	C _{n+1} Control specimen	Cut Index	± 0.64	Level 0
	Left	0.8	0.1	1.1	1.11		
		1.1	0.1	0.8	1.11		
		0.8	0.1	0.8	1.13		
		0.8	0.1	0.8	1.13		
		0.8	0.1	1.1	1.11		
	Mean				1.11		
	Right	0.8	0.1	0.8	1.13		
		0.8	0.1	0.8	1.13		
		0.8	0.1	1.1	1.11		
		1.1	0.1	0.8	1.11		
0.8		0.1	1.1	1.11			
Mean				1.11			
OLFA ® RB 45 mm blades used N° 14861 cotton canvas used from Tenthorey De La Plaine							
6.4 Tear resistance	Sample	Peak force / N			± 1.8 N	Level 0	
	1	2.0					
	2	1.4					
	3	0.9					
	4	1.0					
6.5 Puncture resistance	Sample	Peak force / N			± 1.9 N	Level 0	
	1	21.3					
	2	13.5					
	3	17.8					
	4	20.1					

ADDITIONAL INFORMATION /NOTES

Note ⬤ – Estimated uncertainty of measurement applied at point of test (e.g. to applied force or to tolerance limits) to ensure product meets requirements of the standard.

End of Report

Customer details: SATRA Technology Services (Dongguan) Ltd SATRA reference: CHM0329706/2215/CC
Unit 110, Xinzhongyin Garden Your reference: CHT0328812
Hongwei Road Date of report: 25th April 2022
Xiping, Nancheng District Samples received: 11th April 2022
DONGGUAN CITY Date(s) work carried out: 11th to 25th April 2022
Guangdong Province
China
523079

TECHNICAL REPORT

SATRA Technology Services (Dongguan) Ltd:

Customer: Shandong Intco Medical Products Co Ltd
Qiwang Road, Naoshan Industrial Park
Qingzhou
Shandong
262506
China

Subject: EN 16523-1:2015+A1:2018 resistance to permeation by chemicals on gloves described as Nitrile gloves, colour: orange, black.

Conditions of Issue:

This report may be forwarded to other parties provided that it is not changed in any way. It must not be published, for example by including it in advertisements, without the prior, written permission of SATRA.

Results given in this report refer only to the samples submitted for analysis and tested by SATRA. Comments are for guidance only.

Tests marked # fall outside the UKAS Accreditation Schedule for SATRA.

All opinions and interpretations of results, and the comments based upon them are outside the scope of UKAS accreditation and are based on current SATRA knowledge.

A satisfactory test report in no way implies that the product tested is approved by SATRA and no warranty is given as to the performance of the product tested. SATRA shall not be liable for any subsequent loss or damage incurred by the client as a result of information supplied in the report.

Where values for uncertainty of measurement are included within the report then the uncertainty of the corresponding results are based on a standard uncertainty multiplied by a coverage factor $k=2$, which provides a coverage probability of approximately 95%.

When reporting results against a conformance statement (Pass/Fail or the allocation of a class or level) then uncertainty of measurement is taken into account based on a non-binary acceptance which itself is based on the guard band being equal to the expanded uncertainty.

Where the result corrected for uncertainty falls within the tolerance of the conformance statement then the risk of the conformance statement being a false accept or false reject is up to 2.5% and SATRA will in this instance quote a Pass/Fail, class or level.

Where the result corrected for uncertainty falls outside of the tolerance of the conformance statement then the risk of the conformance statement being a false accept or false reject is up to 50%. In this instance SATRA will not provide a Pass/Fail statement or a class or level but will include information in the notes in relation to the result obtained.

Please note that where uncertainty of measurement values have not been included then uncertainty has not been applied to these results. SATRA uncertainty of measurement values are however available upon request.

Report signed by: Chelsea Craig
Position: Technical Administrator
Department: Chemical & Analytical Technology

(Page 1 of 12)

WORK REQUESTED:

Samples of gloves described as Nitrile gloves, colour: orange, black were received on the 11th April 2022 for testing in accordance with EN 16523-1:2015+A1:2018 and assessment in accordance with the requirements of EN ISO 374-1:2016+A1:2018.

SAMPLES SUBMITTED:



Samples described as Nitrile gloves, colour: orange

Samples described as Nitrile gloves, colour: black

CONCLUSION:

When assessed in accordance with the requirements of EN ISO 374-1:2016+A1:2018 the samples of gloves described as Nitrile gloves, colour: orange, black achieved the following performance levels:

Chemical	Performance level
n-Heptane (CAS: 142-82-5)	The samples tested did not meet with the minimum breakthrough time for a performance level 1 to be achieved
40% Sodium hydroxide (CAS: 1310-73-2)	6
96% Sulphuric acid (CAS: 7664-93-9)	1
25% Ammonium hydroxide (CAS: 1336-21-6)	6
30% Hydrogen peroxide (CAS: 7722-84-1)	4
37% Formaldehyde (CAS: 50-00-0)	5

Full results are reported in the following tables.

TESTING REQUIRED:

- EN 16523-1:2015+A1:2018 - Determination of material resistance to permeation by chemicals - Part 1: Permeation by liquid chemical under conditions of continuous contact

RESULTS AND REQUIREMENTS:


EN ISO 374-1:2016+A1:2018 - Protective gloves against dangerous chemicals and micro-organisms - Part 1: Terminology and performance requirements for chemical risks. Table 1: Permeation performance levels.

Permeation performance level	Measured breakthrough time (minutes)
1	>10
2	>30
3	>60
4	>120
5	>240
6	>480


Performance levels are based on the lowest individual result achieved per chemical.

Test/Property	Sample reference:	Nitrile gloves, colour: orange, black		Performance
EN 16523-1:2015 +A1:2018 in accordance with SATRA SOP CAT-005 Using stainless steel permeation cells with standardised dimensions	Test information:	Chemical: n-Heptane		The samples tested did not meet with the minimum breakthrough time for a performance level 1 to be achieved
		Normalised permeation rate (NPR): 1 µg/cm ² /min		
		Detection technique: GC-FID (periodic measurement)		
		Collection medium: Dry air (open loop)		
		Collection medium flow rate: 335 – 380 ml/min		
	Test temperature: (23 ± 1) °C			
	Specimen	Thickness (mm)^Δ	Breakthrough time (mins)[▲]	
	1 – Orange	0.28	27	
	2 – Black	0.24	78	
	3 – Orange	0.26	7	
4 – Orange	0.25	53		
5 – Black	0.24	42		
6 – Orange	0.27	71		
Test result:		7		
UoM:		<1		
Visual appearance of specimens after testing:		Severely swollen		


In accordance with clauses 8.5.1.2 and 8.5.1.4, the test results were outside the defined range and required an additional 3 specimens to be tested. All 6 results have been reported and the sample was found to not meet with the minimum breakthrough time for a performance level 1 to be achieved.




Test/Property	Sample reference:	Nitrile gloves, colour: orange, black		Performance	
EN 16523-1:2015 +A1:2018 in accordance with SATRA SOP CAT-009 Using PTFE permeation cells with standardised dimensions	Test information:	Chemical: 40% Sodium Hydroxide		Level 6	
		Normalised permeation rate (NPR): 1 µg/cm ² /min			
		Detection technique: Conductimetry (continuous measurement)			
		Collection medium: Deionised water (closed loop)			
		Collection medium stirring rate: 45 – 65 ml/min (each cell constant to within ± 10%)			
	Test temperature: (23 ± 1) °C				
	Specimen	Thickness (mm)Δ	Breakthrough time (mins)		
	1 – Orange	0.26	>480		
	2 – Black	0.29	>480		
	3 – Orange	0.24	>480		
Test result:		>480			
UoM:		<1			
Visual appearance of specimens after testing:		Slightly Swollen and slightly discoloured			



Test/Property	Sample reference:	Nitrile gloves, colour: orange, black		Performance
EN 16523-1:2015 +A1:2018 in accordance with SATRA SOP CAT-009 Using PTFE permeation cells with standardised dimensions	Test information:	Chemical: 96% Sulphuric Acid		Level 1
		Normalised permeation rate (NPR): 1 µg/cm ² /min		
		Detection technique: Conductimetry (continuous measurement)		
		Collection medium: Deionised water (closed loop)		
		Collection medium stirring rate: 45 – 65 ml/min (each cell constant to within ± 10%)		
	Test temperature:	(23 ± 1) °C		
	Specimen	Thickness (mm)Δ	Breakthrough time (mins)	
	1 – Orange	0.23	16	
	2 – Black	0.23	18	
	3 – Orange	0.29	17	
		Test result:	16	
		UoM:	<1	
Visual appearance of specimens after testing:		Swollen and discoloured		




Test/Property	Sample reference:	Nitrile gloves, colour: orange, black		Performance
EN 16523-1:2015 +A1:2018 in accordance with SATRA SOP CAT-025 Using PTFE permeation cells with standardised dimensions	Test information:	Chemical: 25% Ammonium hydroxide		Level 6
		Normalised permeation rate (NPR): 1 µg/cm ² /min		
		Detection technique: Ion Chromatography with conductivity detector (periodic measurement)		
		Collection medium: Deionised water (closed loop)		
		Collection medium stirring rate: 45 – 65 ml/min (each cell constant to within ± 10%)		
		Test temperature: (23 ± 1) °C		
	Specimen	Thickness (mm)Δ	Breakthrough time (mins)	
	1 – Orange	0.27	>480	
	2 – Black	0.25	>480	
	3 – Orange	0.26	>480	
	Test result:	>480		
	UoM:	<1		
Visual appearance of specimens after testing:	Swollen and discoloured			



Ammonium Hydroxide is determined by discrete sampling; therefore the permeation rate graph is not a smooth curve.

Test/Property	Sample reference:	Nitrile gloves, colour: orange, black		Performance
EN 16523-1:2015 +A1:2018 in accordance with SATRA SOP CAT-025 Using PTFE permeation cells with standardised dimensions	Test information:	Chemical: 30% Hydrogen peroxide		Level 4
		Normalised permeation rate (NPR): 1 µg/cm ² /min		
		Detection technique: Electrochemical detector (periodic measurement)		
		Collection medium: Deionised water (closed loop)		
		Collection medium stirring rate: 45 – 65 ml/min (each cell constant to within ± 10%)		
		Test temperature: (23 ± 1) °C		
	Specimen	Thickness (mm)^Δ	Breakthrough time (mins)[†]	
1 – Orange	0.28	Between 121 to 180		
2 – Black	0.27	Between 181 to 240		
3 – Orange	0.28	Between 121 to 180		
	Test result:	Between 121 to 180		
	UoM:	See below		
Visual appearance of specimens after testing:		Swollen and discoloured		


For SOP CAT-025, where both the P1 and Pu are observed in the same sampling range, uncertainty is expressed as the time difference between the mid-point of the range and the previous sampling time. This uncertainty is included in the reported result.



Hydrogen peroxide is determined by discrete sampling; therefore the permeation rate graph is not a smooth curve.

Test/Property	Sample reference:	Nitrile gloves, colour: orange, black		Performance
EN 16523-1:2015 +A1:2018 in accordance with SATRA SOP CAT-025 Using PTFE permeation cells with standardised dimensions	Test information:	Chemical: 37% Formaldehyde		Level 5
		Normalised permeation rate (NPR): 1 µg/cm ² /min		
		Detection technique: HPLC-DAD (periodic measurement)		
		Collection medium: Deionised water (closed loop)		
		Collection medium stirring rate: 45 – 65 ml/min (each cell constant to within ± 10%)		
		Test temperature: (23 ± 1) °C		
	Specimen	Thickness (mm)	Breakthrough time (mins)	
	1 – Orange	0.25	>480	
	2 – Black	0.25	Between 361 to 480	
	3 – Orange	0.27	>480	
	Test result:	Between 361 to 480		
	UoM:	See below		
Visual appearance of specimens after testing:		Swollen and discoloured		

For SOP CAT-025, where both the P1 and Pu are observed in the same sampling range, uncertainty is expressed as the time difference between the mid-point of the range and the previous sampling time. This uncertainty is included in the reported result.



Formaldehyde is determined by discrete sampling; therefore the permeation rate graph is not a smooth curve.

- △ EN 16523-1:2015+A1:2018 does not require the test specimen thicknesses to be reported, this information is indicative only.
- ▲ The collection medium from each cell is analysed once every 6 minutes. Due to the complexity of the detection technique, the minimum sampling frequency for final results ≤ 60 minutes as specified in table 1 of EN 16523-1:2015+A1:2018 is not possible. Breakthrough time is calculated using linear interpolation between the discrete sampling points.
- ▼ Breakthrough expressed as a range between discrete sampling points where the average permeation rate exceeds the NPR. Due to the complexity of the detection technique, the minimum sampling frequency as specified in table 1 of EN 16523-1:2015+A1:2018 is not possible.

TECHNOLOGY



SATRA Technology Services (Dongguan) Ltd
Unit 110, Xinzhongyin Garden, Xiping
Nancheng District, Dongguan City
Guangdong Province, China 523079
Tel: +86 (0) 769 22888020
email: info@satrafs.com



23871

Customer details: Shandong Intco Medical Products Co Ltd
Qiwang Road, Naoshan Industrial Park
Qingzhou
Shandong
China
262506

SATRA reference: CHT0328812 /2212 /B

Your reference:

Date of report: 25 April 2022

Samples received: 26 March 2022

Date(s) work carried out: 2-14 April 2022

TECHNICAL REPORT

Subject: EN ISO 21420: 2020 size & dexterity & innocuousness test, EN ISO 374-2: 2019 air leak and water leak, EN ISO 374-5: 2016 viruses test on nitrile gloves, colour: orange, black, sizes M7, L8, XL9, XXL10.

Conditions of Issue:

This report may be forwarded to other parties provided that it is not changed in any way. It must not be published, for example by including it in advertisements, without the prior, written permission of SATRA.

Results given in this report refer only to the samples submitted for analysis and tested by SATRA. Comments are for guidance only.

Tests marked # fall outside the UKAS Accreditation Schedule for SATRA.

All opinions and interpretations of results, and the comments based upon them are outside the scope of UKAS accreditation and are based on current SATRA knowledge.

A satisfactory test report in no way implies that the product tested is approved by SATRA and no warranty is given as to the performance of the product tested. SATRA shall not be liable for any subsequent loss or damage incurred by the client as a result of information supplied in the report.

Where values for uncertainty of measurement are included within the report then the uncertainty of the corresponding results are based on a standard uncertainty multiplied by a coverage factor $k=2$, which provides a coverage probability of approximately 95%.

When reporting results against a conformance statement (Pass/Fail) then uncertainty of measurement is taken into account based on a non-binary acceptance which itself is based on the guard band being equal to the expanded uncertainty.

Where the result corrected for uncertainty falls within the tolerance of the conformance statement then the risk of the conformance statement being a false accept or false reject is up to 2.5% and SATRA will in this instance quote a Pass/Fail, class or level.

Where the result corrected for uncertainty falls outside of the tolerance of the conformance statement then the risk of the conformance statement being a false accept or false reject is up to 50%. In this instance SATRA will not provide a Pass/Fail statement or a class or level but will include information in the notes in relation to the result obtained.

Please note that where uncertainty of measurement values have not been included then uncertainty has not been applied to these results. SATRA uncertainty of measurement values are however available upon request.

Report signed by: Adam Zhang
Position: Technologist
Department: China Testing

(Page 1 of 9)



WORK REQUESTED

Samples described as nitrile gloves, colour: orange, black, sizes M7, L8, XL9, XXL10 were received by SATRA on 26 March 2022 for testing in accordance with EN ISO 21420: 2020, EN ISO 374-2: 2019 and EN ISO 374-5: 2016.

SAMPLE SUBMITTED



TESTING REQUESTED

- EN ISO 21420: 2020 Clause 5.1 – Sizing and measurement of gloves
- EN ISO 21420: 2020 Clause 5.2 – Dexterity
- EN ISO 374-2: 2019 Clause 7.2 – Air leak
- EN ISO 374-2: 2019 Clause 7.3 – Water leak
- EN ISO 374-5: 2016 Clause 5.3 – Protection against viruses (ISO 16604: 2004 Procedure B)
- EN ISO 21420: 2020 Clause 4.2 – Innocuousness of protective gloves

CONCLUSION

The samples described as nitrile gloves, colour: orange, black, sizes M7, L8, XL9, XXL10 were found to achieve the following results:

- EN ISO 21420: 2020 Clause 5.1 – See below table
- EN ISO 21420: 2020 Clause 5.2 – Level 5
- EN ISO 374-2: 2019 Clause 7.2 – Pass
- EN ISO 374-2: 2019 Clause 7.3 – Pass
- EN ISO 374-5: 2016 Clause 5.3 – Pass
- EN ISO 21420: 2020 Clause 4.2 – Pass pH value and PAHs

Detailed results are included on the following page(s)

TESTING

Testing was carried out in accordance with EN ISO 21420:2020 and EN ISO 374-2: 2019

Samples for testing were conditioned for at least 24 hours in a conditioned environment maintained at (23 ± 2) °C and (50 ± 5) % relative humidity.

REQUIREMENTS

Table 1 – Requirements for EN ISO 21420: 2020 Clause 5.2 Dexterity

Performance level	1	2	3	4	5
Diameter of dexterity pin /mm	11.0	9.5	8.0	6.5	5.0

Table 2 – Requirements for EN ISO 374-2: 2019

Clause 7.2 Air leak	No leak to be detected
Clause 7.3 Water leak	No leak to be detected

TEST RESULTS

Table 3 – EN ISO 21420:2020 Test Results

Clause / Test	Requirement	Test Results			UoM (See note ⚡)	Result	
5.1 Glove length, comfort and fit	N/A	Size	Length /mm			± 1.10 mm	N/A
			1	2	3		
		7	248	250	250		
		Comfortable on fit					
		8	242	242	242		
		Comfortable on fit					
		9	253	252	253		
		Comfortable on fit					
		10	259	259	263		
		Comfortable on fit					
5.2 Dexterity	See table 1	Size	Minimum pin diameter / mm			N/A	Level 5
		7	5.0				
		8	5.0				
		9	5.0				
		10	5.0				

Table 4 – EN ISO 374-2: 2019 Test Results

Clause / Test	Test Results		UoM	Result
7.2 Air leak test	Total air pressure used	2.9 kPa	± 0.25 kPa	Pass
	Sample size	Leaks		
	7	No leaks detected		
	8	No leaks detected		
	9	No leaks detected		
10	No leaks detected			
7.3 Water leak test	Sample size	Leaks	NA	Pass
	7	No leaks detected		
	8	No leaks detected		
	9	No leaks detected		
	10	No leaks detected		

ADDITIONAL INFORMATION / NOTES

Note ♦ – Estimated uncertainty of measurement applied at point of test (e.g. to applied force or to tolerance limits) to ensure product meets requirements of the standard

PROTECTION AGAINST VIRUSES TEST RESULTS

Testing was conducted at a third-party laboratory and reported under their reference 220074309. The laboratory is CNAS accredited to ISO 17025: 2017 with ISO 16604: 2004 included in their accreditation schedule.

Table 1 – Resistance to penetration by blood-borne pathogens results

Sample description: Nitrile gloves, colour: orange						
Test method	Specimen	Step 1 (0 kPa, 5 min)	Step 2 (14 kPa, 1min)	Step 3 (0kPa, 4min)	Titre of phage Phi-X174 (PFU /mL)	Comment
ISO 16604: 2004 Procedure B Using retaining screen	+ control	Penetration	Penetration	Penetration	Penetration	Acceptable
	- control	No penetration	No penetration	No penetration	< 1	Acceptable
	1	Invisible penetrate	Invisible penetrate	Invisible penetrate	< 1	Pass
	2	Invisible penetrate	Invisible penetrate	Invisible penetrate	< 1	Pass
	3	Invisible penetrate	Invisible penetrate	Invisible penetrate	< 1	Pass
Sample description: Nitrile gloves, colour: black						
Test method	Specimen	Step 1 (0 kPa, 5 min)	Step 2 (14 kPa, 1min)	Step 3 (0kPa, 4min)	Titre of phage Phi-X174 (PFU /mL)	Comment
ISO 16604: 2004 Procedure B Using retaining screen	+ control	Penetration	Penetration	Penetration	Penetration	Acceptable
	- control	No penetration	No penetration	No penetration	< 1	Acceptable
	1	Invisible penetrate	Invisible penetrate	Invisible penetrate	< 1	Pass
	2	Invisible penetrate	Invisible penetrate	Invisible penetrate	< 1	Pass
	3	Invisible penetrate	Invisible penetrate	Invisible penetrate	< 1	Pass

INNOCUOUSNESS TEST RESULTS

Testing was conducted at a third-party laboratory and reported under their reference A220402048001. The laboratory is CNAS accredited to ISO 17025: 2017.

Sample Item	Sample Description	Location	Style
I001	Orange nitrile gloves	Gloves	1
I002	Black nitrile gloves	Gloves	2

pH Value - EN ISO 21420:2020

Test Method I : With reference to EN ISO 4045:2018, analyzed by pH meter.

Test Method II: With reference to ISO 3071:2020, analyzed by pH meter.

Requirement:	3.5-9.5
--------------	---------

Test Item(s)	Unit	Result	
		I001	I002
Test Method	-	II	II
Parameter	-	-	-
pH Value of Extracting Solution	-	6.11	6.11
Temp. of Aqueous Extract	deg. C	25.1	25.1
pH Value of Aqueous Extract	-	6.6	6.5
Difference Figure	-	-	-
Conclusion	-	PASS	PASS

Note / Key : deg. C = degree Celsius (°C) Temp. = Temperature

Remark: Result(s) was (were) reported the average value from two trials.

Tested part(s) was/were specified by client.

Polycyclic Aromatic Hydrocarbons (PAHs) Content - EN ISO 21420:2020

Test Method : With reference to test method PD CEN ISO/TS 16190:2013

Maximum Allowable Limit:	Each of all listed PAHs: 1.0 mg/kg
--------------------------	------------------------------------

Tested Item(s)	Result			Conclusion
	Detected Analyte(s)	Conc.	Unit	
X001+H002	ND	ND	mg/kg	PASS

Note / Key : ND = Not detected(<Detection Limit) Detection Limit (mg/kg) : Each : 0.2;
mg/kg = milligram per kilogram = ppm = part per million

Remark: The list of polycyclic aromatic hydrocarbons is summarized in table of Appendix.
Tested part(s) was/were specified by client.
Composite testing(s) was/were specified by client.

APPENDIX					
List of Polynuclear Aromatic Hydrocarbons:					
No.	Name of Analytes	CAS-No.	No.	Name of Analytes	CAS-No.
1	Chrysene	218-01-9	5	Dibenzo (a,h) anthracene	53-70-3
2	Benzo (a) pyrene	50-32-8	6	Benzo (b) fluoranthene	205-99-2
3	Benzo (e) pyrene	192-97-2	7	Benzo (j) fluoranthene	205-82-3
4	Benzo (a) anthracene	56-55-3	8	Benzo (k) fluoranthene	207-08-9

***** End of Report *****

Test Report

No. TAOHG2203886501

Date: 15 Jun 2022

Page 1 of 5

Client Name : SHANDONG INTOCO MEDICAL PRODUCTS CO., LTD

Client Address : NO.9888,QIWANG ROAD,NAOSHAN INDUSTRY PARK,QINGZHOU,SHANDONG,CHINA

Sample Name : DIAMOND TEXTURED NITRILE GLOVES

The above sample(s) and information were provided by the client.

SGS Job No. : QDHL2205007192CW - QD
 Date of Sample Received : 01 Jun 2022
 Testing Period : 01 Jun 2022 - 15 Jun 2022
 Test Requested : Selected test(s) as requested by the client.
 Test Method(s) : Please refer to next page(s).
 Test Result(s) : Please refer to next page(s).

Result Summary :

Test Requested	Conclusion
Council of Europe Resolution AP (2004) 4 -Overall migration	PASS
Regulation (EC) No 1935/2004 of the European Parliament and of the Council of 27 October 2004 -Sensorial examination odour and taste test	PASS
Council of Europe Resolution AP (2004) 4 -Specific migration of primary aromatic amine	PASS
Council of Europe Resolution AP (2004) 4 -Specific migration of nitrosamine and nitrosatable substances	PASS

Signed for and on behalf of
 SGS-CSTC Standards Technical Services (Qingdao) Co., Ltd.



Wang Bo, Claire
 Approved Signatory

scan to see the report



TAOHG2203886501



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/terms-and-conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/terms-and-conditions/terms-and-conditions-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of SGS document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.
 Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755) 8307 1663, or email: CN.Backcheck@sgs.com

SGS Center, No. 143, Duzhou Road, Laoshan District, Qingdao, Shandong, China 266101 | (86-532) 68998888 | www.sgs.com | sgs.china@sgs.com

Member of the SGS Group (SGS SA)

Test Report

No. TAOHG2203886501

Date: 15 Jun 2022

Page 2 of 5

Test Result(s) :

Test Part Description :

Specimen No.	SGS Sample ID	Description	Material (claimed by the client)
SN1	TAO22-038865.001	Orange rubber glove	Nitrile rubber

Remarks :

- (1) mg/dm² = milligram per square decimeter
- (2) mg/kg = milligram per kilogram
- (3) °C= degree Celsius
- (4) < = less than
- (5) MDL = Method Detection Limit
- (6) ND = Not Detected (< MDL)

Council of Europe Resolution AP (2004) 4 -Overall migration

Test Method : With reference to Commission Regulation (EU) No 10/2011 of 14 January 2011 Annex III and Annex V for selection of condition and EN 1186-1:2002 for selection of test methods;
 EN 1186-9: 2002 aqueous food simulants by article filling method;
 EN 1186-2: 2002 olive oil by total immersion method;

<u>Simulant Used</u>	<u>Time</u>	<u>Temperature</u>	<u>Max. Permissible Limit</u>	<u>Result of 001 Overall Migration</u>	<u>Conclusion</u>
3% Acetic acid (W/V) aqueous solution	0.5hr(s)	40°C	10mg/dm ²	8.2mg/dm ²	PASS
10% Ethanol (V/V) aqueous solution	0.5hr(s)	40°C	10mg/dm ²	6.6mg/dm ²	PASS
Rectified olive oil	0.5hr(s)	40°C	10mg/dm ²	3.5mg/dm ²	PASS
Area/Volume			-	10.0dm ² /kg	

Notes :

- (1) Analytical tolerance of aqueous simulants is 2 mg/dm² or 12 mg/kg.
- (2) Analytical tolerance of fatty food simulants is 3 mg/dm² or 20mg/kg.
- (3) Test condition & simulant were specified by client.
- (4) Report the first migration result.
- (5) The test of rectified olive oil simulant was subcontracted to SGS Ningbo chemical lab.

Regulation (EC) No 1831/2003 of the European Parliament and of the Council of 27 October 2003 -Sensorial examination odour and taste test


Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed (where applicable) available on request or accessible at <http://www.sgs.com/Service-Terms-and-Conditions.aspx> and, for electronic format documents, subject to terms and conditions for electronic documents at <http://www.sgs.com/Service-Terms-and-Conditions/Forms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues detailed therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755) 8307 1643, or email: CN.Doccheck@sgs.com

SGS (China) Technical Services (Shanghai) Co., Ltd.

SGS Center, No.143, Zhuchen Road, Luoshan District, Qingdao, Shandong, China 266101 | (86-532) 6868888 | www.sgs.com | sgs.china@sgs.com



Test Report

No. TAOHG2203886501

Date: 15 Jun 2022

Page 3 of 5

Test Method : With reference to DIN 10955: 2004
 Test media: Distilled water
 No. of panelist: 6

Test Item(s)	Limit	001
Test time (hr)	-	0.5
Temperature (°C)	-	40
Sensorial examination odour (Point scale)	2.5	0.0
Sensorial examination taste (Point scale)	2.5	0.0
Conclusion		PASS

Notes :

- Intensity scale (rounded at 0.5):
- 0 – no perceptible difference
 - 1 – just perceptible difference
 - 2 – slight difference
 - 3 – marked difference
 - 4 – strong difference

Council of Europe Resolution AP (2004) 4 -Specific migration of primary aromatic amine

Test Method : With reference to EN 13130-1: 2004, analysis was performed by UV-Vis.

Sample 001

Simulant Used : 3% Acetic acid (W/V) aqueous solution
 Test Condition : 40 °C 0.5 hr(s)

Test Item(s)	Max. Permissible Limit	Unit	MDL	Test result
Migration times	-	-	-	First
Area/volume	-	dm ² /kg	-	6.0
Specific migration of primary aromatic amine	ND	mg/kg	0.01	ND
Conclusion				PASS

Notes :

- (1) Test condition & simulant were specified by client.

Council of Europe Resolution AP (2004) 4 -Specific migration of nitrosamine and nitrosatable substances

Test Method : With reference to EN 13130-1: 2004, analysis was performed by GC-MS.



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/portal/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/portal/Terms-and-Conditions-for-Electronic-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.
 Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-155) 8307 9443, or email: CN.QC@SGS.COM

SGS Center, No.143, Zhuzhou Road, Luchuan District, Jingde, Shandong, China 260171 | (86-532) 68999888 | www.sgs.com | sgs.china@sgs.com

Member of the SGS Group (SGS SA)



Test Report

No. TAOHG2203886501

Date: 15 Jun 2022

Page 4 of 5

Sample 001

Simulant Used : 3% Acetic acid (W/V) aqueous solution

Test Condition : 40 °C 0.5 hr(s)

Test Item(s)	Max. Permissible Limit	Unit	MDL	Test result
Migration times	-	-	-	First
Area/volume	-	dm ³ /kg	-	6.0
Specific migration of Nitrosamines	0.01	mg/kg	0.01	ND
Specific migration of Nitrosatable substances	0.1	mg/kg	0.1	ND

Conclusion

PASS

Notes :

(1) Nitrosamines tested: N-nitrosodimethylamine (NDMA), N-nitrosodiethylamine (NDEA), N-nitrosodipropylamine (NDPA), N-nitrosodibutylamine (NDBA), N-nitrosopiperidine (NPIP), N-nitrosopyrrolidine (NPYR), N-nitrosomorpholine (NMOR), N-nitrosodibenzylamine (NDBzA), N-nitroso-N-methyl-N-phenylamine (NMPHA), N-nitroso-N-ethyl-N-phenylamine (NEPHA), N-nitrosodisononylamine (NDINA) and N-Nitrosodisobutylamine (NDiBA)

(2) Test condition & simulant were specified by client.

(3) The test was subcontracted to SGS Ningbo chemical lab.

Unless otherwise stated, the decision rule for conformity reporting is based on Binary Statement for Simple Acceptance Rule ($w=0$) stated in ILAC-G8:09/2019.



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/Service-Terms-and-Conditions.aspx> and, for electronic formal documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/Service-Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its investigation only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.
Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1663, or email: CN.Qoocheck@sgs.com

SGS (China) Technical Services (Shanghai) Co., Ltd.

SGS Center No.10, Zhuzhen Road, Luchuan District, Qinghai, Shengong, China 200101 | (86-032) 68998868 | www.sgs.com.cn | sgs.china@sgs.com

Member of the SGS Group (SGS SA)



Test Report

No. TAOHG2203886501

Date: 15 Jun 2022

Page 5 of 5

Sample photo:



SGS authenticate the photo on original report only

*** End of Report ***

有限公司



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/sgs/terms-and-conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/terms-and-conditions/terms-and-conditions-form-e-documents.aspx>. Attention is drawn to the limitation of liability, indemnification and arbitration clause detailed therein. Any failure of this document to advise that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.
Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-755) 8307 1663, or email: CN.Document@sgs.com.